



AK Rubber & Industrial Supplies Ltd

SHEETING • MATTING • GASKETS • STRIP • MOULDINGS
EXTRUSIONS • INDUSTRIAL HOSES • FITTINGS • CLIPS • SEALANTS

18 Twyford Business Centre • London Road • Bishop's Stortford • Herts • CM23 3YT
email: sales@akrubber.co.uk Tel: 01279 719000 Fax: 01279 719001

Statement of Product Conformity

Systems Certified to ISO 9001:2008

JP Polymer Sheetings Ltd

Declare that

Live working –Electrical Insulating Matting Class 0 Working Voltage 1000V AC

Is in conformity to IEC61111:2009 under the harmonized national standard BS EN61111:2009.

The product was examined by Smithers Rapra Technology Ltd, Shawbury, Shrewsbury, Shropshire,-SY4 4NR, United Kingdom. An ISO/IEC 17025 accredited laboratory (UKAS 0067). The technical report produced CTR 54696 confirms its conformity to the performed tests stated in the standard EN61111:2009.

Class	Reference	Max Thickness mm	Proof Test AC Voltage	Max Use AC Voltage	Test Report No. Certificate
0	N09 CLASS0	6	5000	1000	CTR 54696

Colour - Black

Surface - Ribbed Corrugations

Mechanical Properties

Puncture Test Not less than 70N

Flame Retardancy Flame not to reach any point on 50mm circle

User Information

No electrical insulating matting, even those held in storage should be used unless they have been inspected and/or electrically tested within the previous 12 months.

10th August 2012